






CONSOLIDATED REPORT ON INSPECTION OF RO WATER PLANTS 2021-22

As per the university circular, Ref. No. VTU/BGMA/NSS/Inspection of RO water plants/ 2021-22/544 dated 28-12-2021, many student teams of Basaveshwar Engineering College, Bagalkote are informed to do the inspection of RO water plants in the allotted gram panchayaths of Bagalkote district in the year 2021-22. All the teams did the inspection on working and usage of RO water plants, as per the format provided by the university and consolidated report is given herewith.

Sl.No	Grama Panchayathi	Habitation/Grama	Working/Usage of RO
1	Timmapur	Timmapur	<p>Panchayathi details: RO plant was started in the year 2014-15 and tendered by KLLADS with expenditure of 2.5lakhs. Source of water is bore well.</p> <p>According to users RO Plant is working in good condition. The quality of drinking water is good. R O Plant is in working for 24 hours. Tank is clean and per 20 litre can 2 rupees they are charging.</p> 
2	Kadampur	Kadampur	<p>Panchayathi details: RO plant was started in the year 2015-2016 with the expenditure of 4.7 lakhs. Source of water is Bore well.</p> <p>According to users RO Plant is in working condition. The quality of drinking water is good. Source of water is Bore well.</p> <p>There is proper power supply to the water plant and is running for 10 hrs in a day. People from this habitation depend on this water plant.</p> 

3	Govindkoppa	Govindkoppa	<p>Panchayathi details: RO plant was started in the year 2015-16 with the expenditure of 4.7lakhs. Source of water is Bore well. It is given to some agency.</p> <p>According to users R O Plant is in working condition. The quality of drinking water is good. There is proper power supply to the water plant and is running 24 hrs in a day. People from this habitation depend on this water plant.</p> 
4	Hullikeri	Yankanchi	<p>Panchayathi details: RO plant was started in the year 2015-16 with the expenditure of 4.7 lakhs. Source of water is Bore well. According to users RO Plant is not working past from 2-3weeks. There is no operator for this unit. Panchayathi workers look after this unit. The present condition was reported to panchayathi officers. People from this habitation depend on this water plant. People of this village can depend on another RO unit of Maninagar.</p> 

5	Bagalkot	Kaulpet	<p>Panchayathi details: RO plant was started in the year 2018-19. It is located in Kaulpet Bagalkot with the expenditure of 3.5lakhs. Source of water is Bore well. It is given to some agency. According to users RO Plant is in working condition. The quality of drinking water is clean and taste. There is proper power supply to the water plant and is running 16hrs in a day. People from this habitation depend on this water plant. Tank and entire surrounding of the plant is kept clean.</p> 
6	Amarawati	Timmapur	<p>Panchayathi details: RO plant was started in the year 2013-14 and tendered to some agency with an expenditure of 2.5lakhs. Currently it is in use. Source of water is Bore well. According to users R O Plant is in working condition for 16 hours. The quality of drinking water is good. Source of water is bore well. There is continuous power supply. Tank is clean.</p> 
7	Kajjidoni	Sharadal	<p>Panchayathi details: RO plant was started in the year 2015-16 with the expenditure of 2.5lakhs tendered to some agency. Currently it is in working condition. Source of water is Bore well.</p>

			<p>According to users the quality of drinking water is good. Source of water is bore well. There is proper power supply to the water plant and presently it is running 24 hrs. Water tank is clean. People from this habitation depend on RO water plant. Water tank is clean.</p> 
8	Shiraguppi	Shiraguppi	<p>Panchayathi details: RO plant was started in the year 2013-14 with the expenditure of 2.5 lakhs. Source of water is Bore well. According to users RO Plant is in working condition. The quality of drinking water is good. There is proper power supply to the water plant and is running 24 hrs in a day. People from this habitation depend on this water plant.</p> 